



ADDENDUM N. 2

“Cooling Tower Repairs” TSC RFP 18-04

The following changes are hereby incorporated into the Request for Proposal “Cooling Tower Repairs” All proposal’s statements submitted for consideration shall be bound by the information contained in this addendum.

***Item Section and Description**

Question and Answer Session

1. On page number six of the RFP document, Section 7 “Description of Services”, Cooling Tower Cell #3 Repairs, second paragraph it refers to the furnishing and installation of a new galvanized steel mechanical equipment support. What type of galvanized steel is required?
Answer: Hot dip galvanized steel.
2. On page number six of the RFP document, Section 7 “Description of Services”, Cooling Tower Cell #3 Repairs, fourth paragraph it refers to furnishing and installing new gear oil. What type of gear oil is required?
Answer: Synthetic gear oil.